

# PRODUCT CERTIFICATE

## Meriser Oy

manufactures

### Merika MekaPjk tap angle boxes

Merika MekaPjk tap angle boxes, Merika code 2237 and 22373, are intended for connecting water pipes in tube to taps.

Eurofins Expert Services Oy has tested the watertightness of MekaPjk tap angle box mounted on a flexible substrate using different waterproofing membranes. As penetration sealant Merika waterproofing flange or the sealant belonging to the waterproofing system was used. Watertightness was tested according to EAD 030352-00-0503, Annex F. The penetration was tested watertight with the following sealants and waterproofing membranes:

Wall penetration	Penetration sealant	Waterproofing membrane	
Merika MekaPjk tap angle box Push Fit 15 mm, Merika code 2237	Merika waterproofing flange for MekaPjk tap angle box, Merika code 23071	ARDEX 8+9	
		Bostik Membrane	
Merika MekaPjk tap angle box 15 mm with compression fitting, Merika code 22373		Casco AquaStop	
		Fescon WS	
		Fintex Vedeneriste 1320	
		Kiilto KeraPro	
		Kiilto Kerafiber	
		Kiilto KeraSafe+	
		Lakka Vedeneriste	
		Mapegum WPS	
		weber WP	
		weber WX	
		ARDEX SRM 50 - 80 pipe sealing collar	ARDEX 8+9
		Bostik pipe sealing collar 30 - 55 mm	Bostik Membrane
		Casco WetStop MG 30 - 60 mm	Casco AquaStop
		Ceresit CL 525 flange	Ceresit CL 51
Fescon VE 40 mm wall packing	Fescon WS		
Fintex Lämpivientivahvike	Fintex Vedeneriste 1320		
Kiilto Lämpivientivahvike 34 - 55 mm	Kiilto KeraPro		
	Kiilto Kerafiber		
	Kiilto KeraSafe+		
Lakka Lämpivientitiiviste	Lakka Vedeneriste		
Mapei Mapeguard PC 32 - 60 mm	Mapegum WPS		
weber SC sealing collar 50 - 60 mm	weber WP		
	weber WX		

<sup>1)</sup> Further clarifications are given on page 2

This certificate is based on testing of the product and inspection of the factory production control according to the certification criteria SERT R003.

This certificate is valid until April 29, 2027 on condition that the product is not essentially changed and the manufacturer and Eurofins Expert Services Oy have a valid contract on quality control. To check the validity of this certificate, [www.sertifikaattihaku.fi](http://www.sertifikaattihaku.fi). Other conditions are listed on page 2.

Espoo, April 29, 2022

Katja Vahtikari  
 Manager, Construction Certification

Tiina Tirkkonen  
 Senior Expert

*This document has been signed electronically*

# PRODUCT CERTIFICATE

No EUFI29-22001881-C/EN  
Issued April 29, 2022

2 (2)

1) Further clarifications:

Waterproofing was installed according to the waterproofing manufacturer's instruction.  
Used waterproofing products:

Manufacturer/Deliverer	Primer	Waterproofing membrane
ARDEX Oy	ARDEX P 51	ARDEX 8+9
Bostik AB	Bostik 6030	Bostik Membrane
Oy Sika Finland Ab	Casco Primer	Casco AquaStop
Henkel Balti Oü	Ceresit R 766	Ceresit CL 51
Fescon Oy	Fescon KP	Fescon WS
Fintex Tetrakem Oy	Fintex Primer 1330	Fintex Vedenerise 1320
Kiilto Oy	Kiilto Keraprimer	Kiilto KeraPro Kiilto Kerafiber
	Liima: Kiilto KeraSafe Speed	Kiilto KeraSafe+
Lakka Rakennustuotteet Oy	Lakka Primer	Lakka Vedeneriste
Mapei Oy	Primer G	Mapegum WPS
Saint Gobain Finland Oy, Weber	weber MS weber MX	weber WP weber WX

Conditions for the validity of the certificate:

Where reference is made in this certificate to any regulations, publications, standards or other documents, it shall be construed as a reference to such publication in the form of which it is in force at the date of this certificate.

The manufacturer is responsible for the quality and continuous quality control of the product. In granting this certificate, Eurofins Expert Services Oy does not accept responsibility to any person or body for any loss or damage incurred in respect of personal injury arising as direct or indirect result of the use of this product.

The use of the name of EurofinsExpert Services Oy or the name Eurofins in any other form in advertising or distribution in part of this certificate is only permissible with written authorisation from Eurofins Expert Services Oy.

This certificate is the English version of the original EUFI29-22001881-C Finnish certificate. In case of dispute the Finnish original of the certificate is valid.